

From

The Head  
Department of Microbiology  
PAU, Ludhiana.

To

The Principal  
Ram Lal Bhasin Pubic School  
Phase 1, Dugri  
Ludhiana

Memo. No. 3789

Dated: 19/10/2020

Subject: Bacteriological quality of drinking water (IS-10500:1991, BIS New Delhi).

Reference is made to your letter No. nil dated 14.10.2020 regarding sample of water for bacteriological analysis.


### REPORT

S. No.	Source	Coliform organisms		Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water Sample	Absent	--	Not Detected


### INFERENCE

**Bacteriologically safe** :- 01

**Bacteriologically not safe** :- nil

  
19/10/2020  
Incharge  
Water Testing Lab  
Department of Microbiology  
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the Univeristy.

  
19/10/2020  
Head  
Department of Microbiology